

Portland Site Profiles



9000 SW Nimbus Ave, Beaverton, OR 97008

Site Type:

Node, Collocation Facility

Equipment:

DACS & Transport Equipment, Diverse Fiber Entrance

Status:

OnNet, Node Facility

Power Protection:

Caterpillar Model 3508B 1000KW, Liebert 225KVA & 125KVA UPS, Lucent Galaxy System DC pwr

Responsible Group:

XO Operations

Video:

Yes

Fire Suppression:

Dry Pipe pre-action & FM-200

Access:

Key card system





10575 SW Cascade Ave, Suite 150, Tigard, OR 97223

Site Type:

Node, Collocation Facility

Equipment:

5E Switch, DACS & Transport Equipment, Diverse Fiber Entrance

Status:

OnNet, Node Facility

Power Protection:

Mitsubishi Mod. S6A3PTA 500KW generator, Mitsubishi 9700 Series UPS, 1200 amp DC Power System w/5 battery strings

Responsible Group:

XO Operations

Video:

No

Fire Suppression:

Interlock pre-action

Access:

Key card system

