

St. Louis Site Profiles



710 N. Tucker Blvd., Suite 410, Saint Louis, MO 63101

Site Type:

Transport / Switch / Collocation Facility

Equipment:

Lucent 5ESS, Alcatel 1630 & 1631 DCS, Diverse Fiber Entrances

Status:

OnNet, Node Facility

Power Protection:

Mitsubishi 750KW backup generator w/2775 gallon diesel fuel capacity, 150 KVA UPS

Responsible Group:

XO Operations

Video Monitoring

Yes

Fire Suppression

Wet Sprinkler

Access:

Scan Card System (ADT)





**2020 Westport Center Drive, Maryland Heights,
MO 63146**

Site Type:

Transport / Switch / Collocation Facility (XO NOCC housed in this office)

Equipment:

Nortel DMS 500, Sonus, Tellabs 5500/ 532,
Diverse Fiber Entrances

Status:

OnNet, Node Facility

Power Protection:

Onan 500KW backup generator w/850 gallon diesel fuel capacity, 125 KVA UPS

Responsible Group:

XO Operations

Video Monitoring

Yes

Fire Suppression

Dry Pipe pre-action & FM-200

Access:

Scan Card System (CAMDEX)





900 Walnut St., Saint Louis, MO 63102

Site Type:

Transport Facility

Equipment:

Core Router, Stl to Chi LH, Stl to Kan LH, Diverse Fiber Entrances

Status:

OnNet, Node Facility

Power Protection:

Telcom Hotel: Generator backup power provided by building owner. No UPS installed in the office.

Responsible Group:

XO Operations

Video Monitoring

No

Fire Suppression

Dry Pipe pre-actions & FM-200

Access:

Scan Card System (Building Owner System)

