

Tampa Site Profile



5904-A Hampton Oaks Pkwy, Tampa FL 33610-9509

Site Type:

Class 5 switch site with DMS 100/250 and Titan DSC equipment. This site provides local service, Long haul Tier I Backbone and collocation facilities

Equipment:

DMS 100/250; Titan DSC Equipment; Sonus Soft switch and SONET equipment

Status:

On Net facility

Power Protection:

3 strings of batteries, Cummins 750KW generator, and a Mitsubishi 9700 Series UPS

Responsible Group:

XO Operations

Video Monitoring

Yes

Fire Suppression

Dry Pipe pre-action & FM-200

Access:

3 Front door and 2 rear door with electronic key card access

